



This policy is for construction staking within the public right-of-way or easement. The staking requirements are for grading and drainage, drainage facilities, sanitary sewer, storm drain, water, concrete, and paving within the public right-of-way or easement. The information shown is the minimum required construction staking for all construction. It is the responsibility of the Inspector to confirm that the construction staking is installed as defined by this policy. The Inspector may allow deviations from the policy when extraordinary field conditions exist.

Sanitary Sewer/Storm Drain

1. Cut stakes shall be set for grade and line at 25-foot intervals and at each manhole. Grades shall be set to the invert of the pipe. The contractor and inspector shall agree upon an offset. Line stakes shall be provided for all services.
2. An offset grade stake shall be set for each manhole.

Water

1. Cut stakes shall be set for grade and line at 50-foot intervals. Grades shall be set to the invert of the pipe. Line stakes shall be provided for all services, fittings, and other critical points. The contractor and inspector shall agree upon an offset.
2. Offset stakes shall be set for the location and grade of the fire hydrants.

Curb and Gutter

1. Curb stakes shall be set to grade (i.e., bluetops) and tacked for line at 25-foot intervals. The contractor and inspector shall agree upon an offset.
2. Cut and fill stakes will be allowed only in instances where offset grades preclude the setting of stakes to grade.
3. Control point stakes (i.e., grade breaks, angle points, transitions, end of aprons, returns, etc.) shall be set to grade, tacked to line, and provided with distinct flagging to differentiate from curb and gutter staking.
4. A reference hub shall be installed for each control point stake.

Sidewalks

1. Staking of sidewalk is not required if it is installed adjacent to the curb.
2. Stakes shall be set to line and grade on 25-foot intervals for detached sidewalks.
3. Stakes shall be installed for all control points.

Paving

1. Centerline subgrade shall be staked to grade at 50-foot intervals. Streets wider than 40 feet from the face of curb to face of curb shall also be staked to grade at 1/4 points at 50-foot intervals.
 2. Centerline ABC shall be staked to grade at 50-foot intervals. Streets wider than 40 feet from the face of curb to face of curb shall also be staked to grade at 1/4 points at 50-foot intervals.
 3. After paving, locations for monuments shall be re-established, and after installation, monuments shall be punched.
 4. Following paving, the locations of all utilities that are to be adjusted shall be re-established.
-