



<b>Issue Date:</b>	September 7, 2021
<b>Code/Section:</b>	1109.2 exception 3
<b>Developed By:</b>	Rost Sapon, Accessibility Technical Lead

**Issue:**

Section 1109.2 exception 3 allows at least 50 percent, rather than all, of the multiple single-user bathing rooms that are clustered in a single location to be *accessible*. The Americans with Disabilities Act Section 213.2 exception 4 does not allow this reduction in *accessible* bathing rooms.

**Interpretation:**

For facilities that are required to comply with the Americans with Disabilities Act delete the words "or bathing rooms" in Section 1109.2 exception 3.