The following is a list of items to be checked when reviewing elevator plans and the following codes as part of the Phoenix Building Construction Code (PBCC) with amendments: 2017 National Electrical Code (NEC), 2016 ASME A17.1 Safety Code for Elevators and Escalators, and 2018 International Building Code (IBC).

MISCELLANEOUS REQUIREMENTS

- \Box Emergency power IBC, Section 2702
- □ Type of elevator and number of elevators
- □ Elevator requirement per IBC Amendment, Section 3002.4
- □ Layout drawings for machine room
- □ Power operation hoistway and car doors A17.1, Section 2.13.2.1
- □ Video Text to Talk Communications IBC 3002.1 A17.1 2019 Section 2.27.1.1.3

PIT REQUIREMENTS

- □ Ladder A17.1, Section 2.2.4.2.1
- □ Lighting A17.1, Section 2.7.9.1
- □ Pit, Ground Fault Circuit Interruption (GFCI) NEC, Section 620
- □ Luminated Light Switch NFPA 70 Section 110.26D

HOISTWAYS REQUIREMENTS

- \Box Heating and A/C A17.1 Amendment, Section 2.8.5
- □ Lighting A17.1, Section 2.7.9.1
- \Box Upward movement A17.1, Section 2.4.7.2
- \Box Governor access A17.1, Section 2.7.6.3.4
- □ Cartop Handrails A17.1 Section 2.14.1.7.1

MACHINE ROOM, CONTROL SPACES, MACHINERY SPACES AND CONTROL ROOM REQUIREMENTS

- □ Two-way communication A17.1, Section 2.27.1.1.1
- \Box GFCI NEC, Section 620.85
- □ Car lighting disconnect NEC, Section 620.53
- □ Elevator disconnect NEC, Section 620.51
- □ Access to machine room, control spaces, machinery spaces and control rooms A17.1, Section 2.7.3
- □ Phone line A17.1, Section 2.27.1.1.1
- \Box Fire extinguishers A17.1, Section 8.6.1.6.5
- \Box Clearances A17.1, Section 2.7.4
- □ Air Conditioning A17.1 Amendment, Section 2.8.5
- □ Luminated Light Switch NFPA 70 Section 110.26D

For more information or for a copy of this publication in an alternate format, contact Planning & Development at 602-262-7811 voice or TTY use 7-1-1.