CITY OF PHOENIX WATER SERVICES DEPARTMENT ENVIRONMENTAL SERVICES DIVISION 2474 SOUTH 22ND AVENUE, BUILDING 31 PHOENIX, ARIZONA 85009-6918 602) 262-1859 PHOENIX.GOV/ESD



INTERCEPTOR ABANDONMENT

In some instances, interceptors may be located in a location such that its removal could endanger the structural integrity of another tank or structure. In these cases, interceptors may be abandoned in-place and must meet specific abandonment requirements.

- 1. Piping shall be rinsed and drained back into the interceptor.
- 2. All residual liquid, solids, or sludge shall be removed from the interceptor, and handled and disposed of properly by a permitted disposal facility.

 Documentation showing disposal by a permitted facility shall be submitted to the City of Phoenix.
- 3. Associated electrical and mechanical components shall be disconnected and removed from the interceptor. The only exception to this is if the electrical power services some other equipment which is not being closed (i.e.: the cathodic protection system).
- 4. Cut and plug both ends of the abandoned sewer drain pipe between the building and the interceptor not more than five feet outside the building foundation, if practical, or cut and plug as close to each end as possible. All fill and access locations and piping shall be cut and/or sealed using locking caps or concrete plugs.
- 5. Closure may be accomplished by either of the following two methods:
 - a. Remove the entire interceptor: Call 602-495-7412 for an inspection prior to backfilling the cavity following interceptor removal.
 - b. <u>Abandon-in-place</u>: Call 602-495-7412 for an inspection prior to filling the interceptor to ensure that the interceptor contents have been removed (2), electrical/mechanical components have been disconnected (3), and inlet/outlet piping has been cut and plugged (4).
- 6. After inspection and approval, fill the (a) cavity or (b) interceptor with approved material consisting of earth, sand, pea gravel, concrete, or other approved fill material.
- 7. Regrade the surface to provide drainage and/or seal manhole covers to prevent inflow.
- 8. Provide and maintain documentation showing that all of the above requirements have been met.

If you have any questions regarding this supplement or any other pretreatment issues, please call the City of Phoenix, Environmental Services Division at (602) 262-1859, Monday through Friday, 8:00 a.m. to 4:30pm.

REFERENCE:

Uniform Plumbing Code Chapter 10, Section 1014.3.7 - Abandoned Gravity Grease Interceptors

Page 1 of 1 04/2017